



Certified Validation Report Part A: Provided by Validator

Validator Provided

Audit Information:

Water Supplier Name: Rio Linda Elverta CWD

PWS ID: 3410018

System Type: Potable

Audit Period: Calendar 2019

Utility Representation: Pat Goyet (Operations Superintendent)

Validation Date: 9/28/2020

Sufficient Supporting Documents Provided: *YES*

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 57

Data Validity Band (Level) **III**

ILI: 3.19

Real Loss: 36.84

Apparent Loss: 8.45

Non-revenue water as percent of cost of operating system:

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator: Timothy R. Shaw

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA



Certified Validation Report Part B: Provided by Utility

Utility Provided

Utility: Rio Linda Elverta Community Water District

Water System ID #: 3410018

Water Audit Period: Calendar 2019

Water Audit & Water Loss Improvement Steps

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

- Budget restrictions have been identified in past validation reports. Last year's report accurately reflects an RFP for a rate structure consultant. The rate study is now underway the principle elements of the study have been reviewed with the Board. These principle elements and preliminary structure includes elimination of the metered-not-billed component of the existing rate structure.
- The District is formally engaged in a collaborative with several other water agencies in the region to advance collaboration. One of the areas identified by this process is meter testing. Additionally, the existing AMI software was upgraded to a more current and higher functioning version.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the methods adopted by the American Water Works Association, as contained in their manual, Water Audit and Loss Control Programs, Manual M36, Fourth Edition and in the Free Water Audit Software version 5.

Executive Name (Print)

Patrick Goyet

Executive Position

Operations Superintendent

Signature

A handwritten signature in blue ink, appearing to read "Patrick Goyet", is written over a horizontal line.

Date

01/29/2020